

2/22/2016

Additional questions submitted by vendors for the PSIM RFP. Answers are in red

Intercom Control

On the intercom function do the 7 stations need to be able to communicate with each other, or just from each station to the intercom locations. The 7 stations are called masters, Do the Masters need to be able to communicate with each other. **ONLY MASTER CONTROL SHOULD TALK TO ALL LOCATIONS. EACH STATION ONLY TALKS BACK TO MASTER CONTROL. NO COMMUNICATION VIA INTERCOM FROM TOWER TO TOWER OR TO MEDICAL OR COURT HOLDING ETC. IS NEEDED.**

Central Control

- 1) It was mentioned that the new video monitors only need to show the original analog cameras and to use those images for the camera call-up functions. Is that correct? **CORRECT**
It was said that the large GeoVision screen in the closet behind the elevator needed to be incorporated into Central Control. Please explain what the desire is for this monitor. **THE MONITOR LOCATED AT THE JAIL SGT. CLOSET IN MASTER CONTROL. TO PROVIDE MASTER CONTROL OPERATORS THE ABILITY TO WATCH ADDITIONAL CAMERAS OUTSIDE OF THE PSIM CONSOLE ON A SEPARATE MONITOR.**
- 3) Do you want the new display camera and monitor in the corner of the desk to be incorporated into the CCTV system? **YES, AS WELL AS THE ONES IN THE DIAGRAM ATTACHED.**
- 4) Would you like the elevator controls to be incorporated into the new touch screens? What about the vehicle gates? **ELEVATOR CONTROLS. ALL GATES (6 TOTAL) ARE DIRECT CONTACT OPERATOR MUST PRESS AND HOLD THE BUTTON DURING OPENING. (AUTOMATIC OPEN AND CLOSE FEATURES ARE NOT NEEDED)**

Nurse Station

If this panel could be re-used in this location would you like the option to leave it or should it be replaced with a touch screen as well? **NO. ALL OPERATOR PANELS TO BE REPLACED WITH A TOUCH SCREEN CAPABLE SYSTEM. WITH THE ABILITY FOR CONTROL TO BE TAKEN BY MASTER CONTROL.**

Dayroom Control Areas

Is the large GeoVision screen showing the new 360° IP cameras and the original analog fixed cameras? Or are those new fixed cameras tied in locally with the GeoVision Video Servers? **YES. THE 360 IP CAMERAS GO DIRECTLY INTO THE MASTER NVR'S. WE ARE USING 3 GEOVISION ENCODER MODEL # GV-VS04H AT EACH TOWER FOR THE REPLACED ANALOG CAMERAS THAT REPLACED THE TOWER PTZ CAMERAS. (SOME ANALOG CAMERAS ARE STILL THE ORIGINAL PTZ CAMERA.)**

Holding Area

If this panel could be re-used in this location would you like the option to leave it or should it be replaced with a touch screen as well? **NO. ALL OPERATOR PANELS TO BE REPLACED WITH A TOUCH SCREEN CAPABLE SYSTEM. WITH THE ABILITY FOR CONTROL TO BE TAKEN BY MASTER CONTROL.**

Sally Port Area

1) Are each of the two new man gates to get:

Intercom
Camera Views

MASTER POLE CAMERA TO OVER LOOK THE MASTER CONTROL OPERATOR (A FISHEYE CAMERA IS NOT included in list below)

Lock Control

If yes to lock control – Who provides the lock? **VENDOR TO PROVIDE LOCK KEYS TO OPERATE AND SECURE EACH**

What type?

GRADE WITH KEY. (BOTH GATES CAN PROVIDE THE ADDITIONAL MATERIALS FOR A CONTROL ACCESS SYSTEM.

2) Can the conduit be mounted on the fence or must it be buried up to the building? **METAL CONDUIT OR EQUIVALENT CONDUIT MATERIAL**

ADDITIONAL CAMERAS TO BE ADDED AND INCLUDED IN THE CCTV SYSTEM


Vendor to provide cameras and materials for installation.

[Redacted]	or equivalent
[Redacted]	chen Sallyport entrance
[Redacted]	Sallyport
[Redacted]	holding
[Redacted]	ell
[Redacted]	ions
[Redacted]	ount or equivalent
[Redacted]	ig Jail Admin & kitchen door
[Redacted]	ig Booking & Sallyport entrance
[Redacted]	ig tower 1 floor & Jail Sgt entrance
[Redacted]	ng Medical entrance
[Redacted]	y to Court Holding
[Redacted]	ourt Holding
[Redacted]	rney Booth hallway
[Redacted]	1 General Sessions by Juvenile Detention to Court Holding.



PROYECTO DE
CONSTRUCCIÓN DE
UN CENTRO DE
ESTUDIOS

PLANTA



Planta
S



BOYBOS 03/12
DISEÑO: BOYBOS
DIBUJOS:
CHECKEADO:

A0.0