

AMENDMENT NUMBER 1 TO THE BID DOCUMENTS

Amendment Date: October 2, 2018

2018103002-BOE  
BHS Baseball Field House HVAC

A. This Amendment shall be considered part of the bid documents for the above mentioned project as though it had been issued at the same time and shall be incorporated integrally therewith. Where provisions of the following supplementary data differ from those of the original bid documents, this Amendment shall govern and take precedence. BIDDERS MUST SIGN THE AMENDMENT AND SUBMIT IT WITH THEIR BIDS.

B. Bidders are hereby notified that they shall make any necessary adjustments in their estimates as a result of this Amendment. It will be construed that each bidder's proposal shall be in accordance with the following:

1. The electrical requirement, for the equipment, was listed incorrectly. See below:

x 208/230v; single phase

2. The installation is clarified to include the following:

x Electrical connection and any incidental materials including disconnects, wire, breakers, fuses, conduit, etc.

o ~~NOTE: Bidders are to supply the Electrical Trade Co. and 2007/ET 1.174~~