

FEBRUARY 5, 2020

SUMNER COUNTY SCHOOLS – GHS TICKET BOOTH

TO:

All Prime bidders and all others whom have received drawings and specifications This Addendum forms part of the Contract documents. It supplements and modifies them as follows:

ACCEPTABLE SUBSTITUTION TO BID DRAWINGS

1. Reduce footer from 2' wide x 1' deep to 16" wide x 12" deep with 2 runs of #4 rebar on chairs.
2. Eliminate #5 vertical rebar 2' O/C and core filled corners.
3. Eliminate laminated beam in breezeway and replace with adequate framing for 8' span.